

# VILLAGE OF CASTLETON-ON-HUDSON WATER AND WASTEWATER REPORT

July 08, 2019

Average daily water flow for March 95,000 GPD

Average daily water flow for April 95,000 GPD

Average daily water flow for May 114,000 GPD

Average daily water flow for June 109,000 GPD

- Repaired a curb stands on VanBuren, Boltwood, and Campbell.
- Helped DPW black top.
- Final water meter readings.
- Gave Matt with Schodack Schools a copy of the water main plans and the bids that came in to replace the water main under the gym.
- Checked for water leaks in our water system.
- Made water meter repairs.
- Marking all water main street valves.
- Mowed and brush hog the water tower.
- 06-30-2019 waterworks alarm booster pump fail.
- Keller was the low bid to move and replace the water main under CES gym.

Average daily sewer flow for March 166,000 GPD

Average daily sewer flow for April 192,000 GPD

Average daily sewer flow for May 173,000 GPD

Average daily sewer flow for June 151,000 GPD

- Purchased a computer to run our new camera for the microscope.
- PW Tec ran a pilot study on their screw press at our plant.
- Checked on a plugged sewer line on Lower Benedict.
- The UV air compressor needed a new motor, check valve, and pressure switch.
- 06-30-2019 power was out at the WWTP for 5.4 hours.
- Joe passed his ABC exam. He is now a licensed WWTP Operator.
- Attended a meeting with Delaware Engineering about a new screw press.

John Shortsleeve

# SEWER REPAIRS 2019

REPAIR SEWER LINE AT CFC

SEWER PUMP LINE REPAIRS AT 3 ANDERSON

REPLACE SEWER LINE AT 9-J AND SEAMAN

CHECK ALL MANHOLES

SMOKE TESTING

BIB OUT SLUDGE TRUCKING

# WATER REPAIRS 2019

## **REPLACE FIRE HYDRANTS**

9-J LAST HYDRANT ON SOUTH END 1952  
SACRED HEART CHURCH  
NORTH MAIN BY REST HOME DRIVEWAY 1964  
123 SCOTT AVENUE 1964  
SEAMAN AT THE TOP OF THE HILL 1965  
NORTH MAIN BETWEEN SCOTT AND SEAMAN 1966  
21 SOUTH MAIN 1966  
STIMPSON AND CHESTNUT 1969  
BRASHEAR 1960  
SCOTT AND SEAMAN 1964  
ALL 7 FIRE HYDRANTS ON MAPLE HILL 1966  
SOUTH SCHODACK AND MAPLE HILL 1966

INSTALL FIRE HYDRANT IN THE MIDDLE OF VANBUREN

## **REPAIR FIRE HYDRANTS**

MAPLE HILL BY WATER TOWER HARD TO OPEN AND CLOSE  
1004 MAPLE HILL OPENS HARD

## **LOCATE FIRE HYDRANT VALVES**

45 SOUTH MAIN  
SCOTT AND NORTH MAIN  
TOP OF THE HILL ON SEAMAN  
52 NORTH MAIN

## **REMOVE FIRE HYDRANTS**

45 SOUTH MAIN  
BEHIND 13 GREEN

## **STREET VALVES**

INSTALL A STREET VALVE AT SEAMAN AND BRASHEAR

REPLACE STREET VALVES AT  
SEAMAN AND BOLTWOOD  
STIMPSON AND 9-J  
SEAMAN AND 9-J

SCOTT AND GREEN INSTALL A VALVE  
SCOTT AND SEAMAN INSTALL A VALVE  
EXERCISE ALL STREET VALVES

## **CURB VALVES AND STANDS**

LOCATE, MARK, AND EXERCISE

6 EDGEWOOD REPAIR CURB STAND

**FIND CURB STANDS**

BRICKYARD- #41 USE CHURCH SHUT OFF IF NEEDED

GLAZ-2,4

HAMILTON – USE PIT OR MAIN ON 9-J

HICKORY – 868

MAPLE HILL – 1288, 1298, 1340, 1354, 1358

PAUL – 12, 14

SCOTT – 35, 38

THICKETT – 1400

**PRESSURE REDUCING VALVES**

INSTALL 2 NEW VALVES AND VAULTS ON SCOTT AND STIMPSON

**WATER MAINS**

REPLACE CAST IRON PIPES FIRST

DRILL NEW WELL BRICKYARD

DRINKING WATER SOURCE PROTECTION

WELL HEAD PROTECTION WITH TOWN OF SCHODACK

PAINT WATERWORKS FLOOR

CLEAN WATERTOWER

FENCE IN GLAZ

CAMERA AT ALL WATER SITES

NEW ROOF AT WATERWORKS

CUT TREES AT LORETTA

UPDATE WATER RULES AND REGS.

WORK WITH BROCK ON WATER GRANT FUNDS

BACKUP GENERATOR FOR WATERWORKS

DRAIN CLEAN AND INSPECT CEMENT WATER STORAGE TANK

CONNECT LYNCH WATER MAIN TO SCOTT WATER MAIN

PULL WELL-A1 CHECK MOTOR AND REPLACE PIPING

**Village of Castleton**  
**Building Department**  
**Monthly Report June 2019**

- 6-3-19 At Village Hall.
- At 28-30 South Main Street – rental unit inspections – four units.
  - At 37 South Main Street – rental unit inspections – 12 units.
  - At 44 Boltwood Avenue - Building Permit#2019-22 – Crandall – final inspection of deck. Project complete. Permit closed.
- 6-4-19 At Village Hall.
- Issued Building Permit#2019-29 – Acierno – 14 Chestnut Street - deck
- 6-5-19 At Village Hall.
- At 42-44 Campbell Avenue - Building Permit#2019-19 – Brewer – footing inspection.
- 6-6-19 At Village Hall.
- 6-10-19 At Village Hall.
- Text and e-mail with Benedict Street resident regarding permit questions.
  - Attended Village Board Meeting.
- 6-11-19 At Village Hall.
- 6-12-19 At Village Hall.
- At 14 Chestnut Street – Acierno - Building Permit#2019-29 – pier footing inspection
  - At 72 Scott Avenue – Bing - Building Permit#2019-26 – fence inspection. Project complete. Permit closed.
- 6-13-19 At Village Hall.
- 6-14-19 At Village Hall.
- At 42-44 Campbell Avenue – Brewer - Building Permit#2019-19 – foundation wall inspection.
- 6-17-19 At Village Hall.
- At 14 Chestnut Street – Acierno - Building Permit#2019-29 -deck framing inspection.
  - Telephone call with property owner of 18 Benedict Street – permit questions.
- 6-18-19 At Village Hall.
- At 55 Campbell Avenue – Megna - Building Permit#2019-25 – final inspection. Project complete. Permit closed.
- 6-19-19 At Village Hall.
- At 3 Stimpson Avenue - Building Permit#2019-11 – Palladino – final inspection. Project complete. Permit closed.
- 6-20-19 At Village Hall.

**Village of Castleton**  
**Building Department**  
**Monthly Report June 2019**

- 6-24-19      At Village Hall.
- At 42-44 Campbell Avenue – Brewer - Building Permit#2019-19 -backfill inspection.
  - Issued Building Permit#2019-30 – Hughes – 12 Campbell Avenue – fence.
  - Issued Building Permit#2019-31 – Teator – 5 Green Avenue – roof.
- 6-28-19      At Village Hall.
- 6-29-19      At Village Hall.
- At 14 Chestnut Street - Building Permit#2019-29 – Acierno – final inspection on deck. Corrections need to be made before permit can be closed.

**July 8, 2019 – Clerk-Treasurer’s Report**

Receivables as of 7/3/19

Property Tax: \$ 433,799.34

Capital Water: \$ 85,200.00

Refuse: \$ 23,245.50

Sewer-Residential: \$ 43,363.50

Sewer-Commercial: \$ 285.00

In Village Residential Water: \$ 13,138.81

Out of Village Residential Water: \$ 12,714.14

In Village Commercial Water: \$ 140.34

Out of Village Commercial Water: \$ 916.51

Out of Village Water Judgements: \$ 0.00

The Village received three bids for the Campbell Avenue Water Line Relocation Project. Results of the bids have been shared with the board a decision will be made at the Board Meeting on June 8, 2019.

Painting of the Village Hall is just about complete. It is asked that the Village Board inspect the Building for any areas that need to be retouched or improved.

Respectfully Submitted,  
Padraic Ellis